



Marco Island Fire Rescue

Department of Fire Prevention

(239)394-5405

danielz@cityofmarcoisland.com

Company/Firm Requesting Test: Davidson Engineering, Inc.

Project Name: Daily Bread Food Pantry

Contact Person & Email: Lee Davidson; lee@davidsonengineering.com

Date Requested: 07/16/2024

Amount Due and Payable to The Marco Island Fire Department \$113____*

*Note: Charges for flow testing will be \$77.00 for the first hydrant and \$36.00 for each additional hydrant tested at the same date and time as the first hydrant.

Remit payment with invoice # to the link below:

<https://marcoislandfl.munisselfservice.com/citizens/GeneralBilling/Default.aspx>

Date Tested: 7/18/24

Location: 1818 San Marco Rd.

Time of Test: 2:35 PM

Pitot: 42 x 2 Static: 80 Residual: 72

Flow: 2,175 gpm

Flow @ 20psi: 6,456 estimated gpm

1280 San Marco Road, Marco Island, FL 34145