



May 6, 2024

Mr. Ryan Williams
Kevin Williams Construction
1857 San Marco Road, Suite 214
Marco Island, FL 34145

Subject: **P230 Polynesia Court**

Dear Mr. Williams,

In June of 2022 Marco Surveying & Mapping performed a survey of 230 Polynesia Court. The process of the survey resulted in a procedural error that resulted in the elevations of the initial survey and the project control too low by 0.5 feet. What we understood to be a 9.1 elevation on our benchmark, was actually an 8.6. At the time of the foundation location the elevations were checked from that benchmark and checked against the project control, failing to indicate that the foundation was too low. This error was completely unintentional and inadvertent.

If there are any questions, please do not hesitate to contact me.

Sincerely,

David Hyatt, PSM
President